

# WEBEL TECHNOLOGY LIMITED

## CORRIGENDUM – II

### TENDER NO. WTL/DDZP/SOLAR/25-26/017 DATED 08.08.2025

Sl. No.	Page No.	Section No.	Description
1	32	I	Revised Technical Specification with Compliance Statement, Section – I is enclosed

## SECTION - I

### TECHNICAL SPECIFICATION WITH COMPLIANCE STATEMENT

(Tender No. WTL/DDZP/SOLAR/25-26/017)

#### A. Details of Solar PV

<b>Make</b>	
<b>Model</b>	
<b>Part No.</b>	

Sl. No.	Component	Details	Specification (Quoted / Applicable – by the bidder)	Complied (Yes / No)
1	Maximum Power (Pm)	585W		
	Maximum Power Voltage (Vm)	43.86		
	Maximum Power Current (Im)	13.34		
	Open Circuit Voltage (Voc)	51.14		
	Short Circuit Current (Isc)	13.90		
	Module Efficiency (m)	22.65%		
	Irradiance	1000W/m2		
	Module Temperature	25°C		
	Type of System	Grid Connected		
	Expected life of Power Plant	25 Years		

# WEBEL TECHNOLOGY LIMITED

## B. Details of Inverter

<b>Make</b>	
<b>Model</b>	
<b>Part No.</b>	

Sl. No.	Component	Details	Specification (Quoted / Applicable – by the bidder)	Complied (Yes / No)
1	Max. recommended PV Power (for Module STC)	78000W		
	Max. DC Voltage	1100V		
	Start Voltage	250V		
	Nominal Voltage	600V		
	MPPT Voltage Range	200V-1000V		
	No. of PV strings per MPP tracker	3/4 + 4+ 4		
	Max. input current per MPP tracker	50A/50A/50A		
	Max. short-circuit current per MPP tracker	55A		
	Warranty	5 Years		

Authorized Signatory (Signature In full): \_\_\_\_\_

Name and title of Signatory: \_\_\_\_\_

Stamp of the Company: \_\_\_\_\_

**Note. Tender Committee may seek OEM Documents, if required.**